Coast Guard, DHS § 118.500

(3) Each storage cylinder in a system must have the same pressure and volume.

(4) Computer programs used in designing systems must be approved by an independent laboratory recognized by the Commandant.

NOTE TO \$118.410(g): As of Jan. 1, 1994, the United States banned the production of Halon. The Environmental Protection Agency placed significant restrictions on the servicing and maintenance of systems containing Halon. Vessels operating on an international voyage, subject to SOLAS requirements, are prohibited from installing fixed gas fire extinguishing systems containing Halon.

[CGD 85–080, 61 FR 917, Jan. 10, 1996; 61 FR 20556, May 7, 1996, as amended at 62 FR 51351, Sept. 30, 1997; USCG–2000–7790, 65 FR 58462, Sept. 29, 2000]

§118.420 Pre-engineered fixed gas fire extinguishing systems.

- (a) A pre-engineered fixed gas fire extinguishing system must:
- (1) Be approved by the Commandant;
- (2) Be capable of manual actuation from outside the space in addition to automatic actuation by a heat detector;
- (3) Automatically shut down all power ventilation systems and all engines that draw intake air from within the protection space; and
- (4) Be installed in accordance with manufacturer's instructions.
- (b) A vessel on which a pre-engineered fixed gas fire extinguishing system is installed must have the following equipment at the operating station:
 - (1) A light to indicate discharge;

- (2) An audible alarm that sounds upon discharge; and
- (3) A means to reset devices used to automatically shut down ventilation systems and engines as required by paragraph (a)(3) of this section.
- (c) Only one pre-engineered fixed gas fire extinguishing system is allowed to be installed in each space protected by such a system.

§118.425 Galley hood fire extinguishing systems.

- (a) A grease extraction hood required by §118.400 of this part must meet UL 710 "Exhaust Hoods for Commercial Cooking Equipment," or other standard specified by the Commandant.
- (b) A grease extraction hood must be equipped with a dry or wet chemical fire extinguishing system meeting the applicable sections of NFPA 17 "Dry Chemical Extinguishing Systems," 17A "Wet Chemical Extinguishing Systems," or other standard specified by the Commandant, and must be listed by an independent laboratory recognized by the Commandant.

Subpart E—Portable Fire Extinguishers

§ 118.500 Required number, type, and location.

(a) Each portable fire extinguisher on a vessel must be of a type approved by the Commandant. The minimum number of portable fire extinguishers required on a vessel must be acceptable to the cognizant OCMI, but must be not less than the minimum number required by Table 118.500(a) and other provisions of this section.

TABLE 118.500(a)

| 175EE 110.000(a) | | | | | | |
|----------------------|---|---------------------------------------|-----------------------|---|--|--|
| Space protected | Minimum number required | Type extinguisher permitted | | | | |
| | | CG class | Medium | Min. size | | |
| Operating station | 1 | B-I, C-I | Halon | 1.1 kg (2.5 lb) 1.8 kg (4 lb) | | |
| Machinery space | 1 | B-II, C-II located just outside exit. | Dry chemical Halon | 0.9 kg (2 lb) 4.5 kg (10 lb) | | |
| Open vehicle deck | 1 for every 10 vehicles | B-II | CO ₂ | 6.8 kg (15 lb) 4.5 kg (10 lb) 9.5 L (2.5 gal) 4.5 kg (10 lb) 6.8 kg (15 lb) | | |
| Accommodation space. | 1 for each 232.3 square meters (2,500 square feet) or fraction thereof. | A-II | Dry chemical Foam | 4.5 kg (10 lb) 9.5 L (2.5 gal) | | |

§ 118.520

TABLE 118.500(a)—Continued

| Space protected | Minimum number required | Type extinguisher permitted | | |
|--|-------------------------|-----------------------------|--------------|-----------------|
| | | CG class | Medium | Min. size |
| | | | Dry chemical | 4.5 kg (10 lb) |
| Galley, pantry, con- cession stand. | 1 | A-II | Foam | 9.5 L (2.5 gal) |
| | | B-II | Dry chemical | 4.5 kg (10 lb) |

- (b) A vehicle deck without a fixed sprinkler system and exposed to weather must have one B-II portable fire extinguisher for every five vehicles, located near an entrance to the space.
- (c) The cognizant OCMI may permit the use of a larger portable fire extinguisher, or a semiportable fire extinguisher, in lieu of those required by this section.
- (d) The frame or support of each B-V fire extinguisher permitted by paragraph (e) of this section must be welded or otherwise permanently attached to a bulkhead or deck.

[CGD 85–080, 61 FR 917, Jan. 10, 1996, as amended at 62 FR 51351, Sept. 30, 1997]

§118.520 Installation and location.

Portable fire extinguishers must be located so that they are clearly visible and readily accessible from the space being protected. The installation and location must be to the satisfaction of the cognizant OCMI.

Subpart F—Additional Equipment

§118.600 Fire axe.

A vessel of more than 19.8 meters (65 feet) in length must have at least one fire axe located in or adjacent to the primary operating station.

PART 119—MACHINERY INSTALLATION

Subpart A—General Provisions

Sec.

119.100 Intent.

119.115 Applicability to existing vessels.

Subpart B—Propulsion Machinery

119.200 General.

119.220 Installations.

Subpart C—Auxiliary Machinery

119.310 Installations.

119.320 Water heaters.

119.330 Pressure vessels.

Subpart D—Specific Machinery Requirements

119.400 Applicability.

119.405 Fuel restrictions.

119.410 General requirements.

 $119.420 \quad Engine\ cooling.$

119.422 Integral and non-integral keel cooler installations.

119.425 Engine exhaust cooling.

119.430 Engine exhaust pipe installation. 119.435 Integral fuel tanks.

119.440 Independent fuel tanks.

119.445 Fill and sounding pipes for fuel tanks

119.450 Vent pipes for fuel tanks.

119.455 Fuel piping.

119.458 Portable fuel systems.

119.465 Ventilation of spaces containing diesel machinery.

119.470 Ventilation of spaces containing diesel fuel tanks.

Subpart E—Bilge and Ballast Systems

119.500 General.

119.510 Bilge piping system.

119.520 Bilge pumps.

119.530 Bilge high level alarms.

119.540 Ballast systems.

Subpart F—Steering Systems

119.600 General.

Subpart G—Piping Systems

119.700 General.

119.710 Piping for vital systems.

119.715 Piping subject to more than 1,034 kPa (150 psig) in non-vital systems.

119.720 Nonmetallic piping materials.

119.730 Nonferrous metallic piping materials.

AUTHORITY: 46 U.S.C. 2103, 3306; E.O. 12234, 45 FR 58801, 3 CFR, 1980 Comp., p. 277; Department of Homeland Security Delegation No. 0170.1.